

Certificate of Analysis

Skyline Mountain Special Services District

Attn: Roy Fox
2201 SMR
Fairview, UT 84629

Work Order: 23G0841
Phone: (801) 361-6227
Fax:
Email: smssd2013@gmail.com

<i>Sample ID:</i> Thads Peak	Report to State: Yes	<i>Lab #:</i> 23G0841-01
<i>Sampled:</i> 7/13/23 9:27	<i>Sampled By:</i> Jeremy Fox	<i>Sample Type:</i> Routine
<i>System #:</i> UTAH20043	<i>Sample Source:</i> DS001	<i>Field Res. Chlorine:</i> Not Provided
<i>Repeat Lab:</i>		<i>Sample Point:</i> DS001
		<i>Original Failure Date:</i>

Parameter Name	Result	Units	Method	Test Started	Test Ended	Flags
Coliform, Total	Absent	Org/100 mL	EPA 9223B	7/13/2023 16:15	7/14/2023 10:15	
E. Coli	Absent	Org/100 mL	EPA 9223B	7/13/2023 16:15	7/14/2023 10:15	

<i>Sample ID:</i> Club House	Report to State: Yes	<i>Lab #:</i> 23G0841-02
<i>Sampled:</i> 7/13/23 9:46	<i>Sampled By:</i> Jeremy Fox	<i>Sample Type:</i> Routine
<i>System #:</i> UTAH20043	<i>Sample Source:</i> DS001	<i>Field Res. Chlorine:</i> Not Provided
<i>Repeat Lab:</i>		<i>Sample Point:</i> DS001
		<i>Original Failure Date:</i>

Parameter Name	Result	Units	Method	Test Started	Test Ended	Flags
Coliform, Total	Absent	Org/100 mL	EPA 9223B	7/13/2023 16:15	7/14/2023 10:15	
E. Coli	Absent	Org/100 mL	EPA 9223B	7/13/2023 16:15	7/14/2023 10:15	



Joyce Applegate, Project Manager

