

Skyline Mountain Resort SSD WS# 20043
CROSS CONNECTION CONTROL POLICY

A policy relating to “cross connection control and backflow-prevention control” at the Skyline Mountain Resort SSD

PART I:

CROSS CONNECTION CONTROL AND BACKFLOW PREVENTION

(1) It shall be against Skyline Mountain Resort SSD policy, at any connection applied with water from the Skyline Mountain Resort SSD distribution system, to do any of the following:

- (a) To install or use any physical connection or arrangement of piping or fixtures, which may allow any fluid or substances unsuitable for human consumption to enter the potable water distribution system, as required by Section 608.1 through 608.5 of the International Plumbing Code.
- (b) To install any connection, arrangement, or fixtures without Backflow Prevention Device or Assembly unless approved otherwise by Maintenance Supervisor.
- (c) To incorrectly install any Backflow Prevention Device or Assembly required by Section 608-.6 and 608.1 of the International Plumbing Code.


(2) Any person found in violation of this policy shall be subject to reprimand or other appropriate disciplinary action as determined by the Maintenance Supervisor.

(3) Administration of this policy shall be referenced by “Cross Connection Control Program of Utah, January 2010 (Guidelines Reference)”. A copy of the manual shall be available at the office of the Maintenance office.

(4) Backflow prevention assemblies required by this policy will be required to be tested at least annually. The Maintenance Supervisor shall prepare and maintain a Backflow Assembly Information sheet on all such devices and Test results shall be maintained for a period of no less than five (5) years.

PART II

This policy shall take effect on May 24, 2016. A copy of the policy shall be placed Maintenance Supervisor office and will be reviewed for all new construction projects on a case by case basis.

Signed: 

Date: 5/23/2016

Title: Operation Manager / Secretary / Clerk