

Certificate of Analysis

Skyline Mountain Special Services District

Attn: Roy Fox
2201 SMR
Fairview, UT 84629

Work Order: 19H0280
Phone: (801) 361-6227
Fax:
Email: rrfox3768@gmail.com

Sample ID: Thad's Peak

Sampled: 8/6/19 9:05

System #: UTAH20043

Repeat Lab:

Report to State: Yes

Sampled By: Jeremy Fox

Sample Source: **WS002**

Lab #: 19H0280-01

Sample Type: Routine

Field Res. Chlorine: Not Provided

Sample Point: **WS002**

Original Failure Date:

Parameter Name	Result	Units	Method	Test Started	Test Ended	Flags
Coliform, Total	Absent	Org/100 mL	EPA 9223B	8/6/2019 15:45	8/7/2019 9:45	
E. Coli	Absent	Org/100 mL	EPA 9223B	8/6/2019 15:45	8/7/2019 9:45	

Sample ID: Lot B-75

Sampled: 8/6/19 9:27

System #: UTAH20043

Repeat Lab:

Report to State: Yes

Sampled By: Jeremy Fox

Sample Source: **DS001**

Lab #: 19H0280-02

Sample Type: Routine

Field Res. Chlorine: Not Provided

Sample Point: **DS001**

Original Failure Date:

Parameter Name	Result	Units	Method	Test Started	Test Ended	Flags
Coliform, Total	Absent	Org/100 mL	EPA 9223B	8/6/2019 15:45	8/7/2019 9:45	
E. Coli	Absent	Org/100 mL	EPA 9223B	8/6/2019 15:45	8/7/2019 9:45	




Joyce Applegate, Project Manager