



12/20/2024

**Work Order: 24L1391**  
**Project: [none]**

**Skyline Mountain Special Services District**

**Attn: Roy Fox**

**2201 SMR**

**Fairview, UT 84629**

**Client Service Contact: 801.262.7299**

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Joyce Applegate, Project Manager



# Certificate of Analysis

**CHEMTECH-FORD**  
LABORATORIES

Lab Sample No.: 24L1391-01

<b>Name:</b> Skyline Mountain Special Services District	<b>Sample Date:</b> 12/17/2024 9:00 AM
<b>Sample Site:</b> Lot-GC 38	<b>Receipt Date:</b> 12/17/2024 1:30 PM
<b>Comments:</b>	<b>Sampler:</b> Jeremy Fox
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b>
<b>PO Number:</b>	<b>System No.:</b> UTAH20043
<b>Source Code:</b> DS001	<b>Sample Point:</b> DS001
	<b>Report to State:</b> Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0138	1.3	0.0012	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	



# Certificate of Analysis

**CHEMTECH-FORD**  
LABORATORIES

Lab Sample No.: 24L1391-02

<b>Name:</b> Skyline Mountain Special Services District	<b>Sample Date:</b> 12/17/2024 7:30 AM
<b>Sample Site:</b> Lot-B 110	<b>Receipt Date:</b> 12/17/2024 1:30 PM
<b>Comments:</b>	<b>Sampler:</b> Jeremy Fox
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b>
<b>PO Number:</b>	<b>System No.:</b> UTAH20043
<b>Source Code:</b> DS001	<b>Sample Point:</b> DS001
	<b>Report to State:</b> Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0055	1.3	0.0012	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	



# Certificate of Analysis

**CHEMTECH-FORD**  
LABORATORIES

**Lab Sample No.: 24L1391-03**

<b>Name:</b> Skyline Mountain Special Services District	<b>Sample Date:</b> 12/17/2024 9:00 AM
<b>Sample Site:</b> Lot-C 49	<b>Receipt Date:</b> 12/17/2024 1:30 PM
<b>Comments:</b>	<b>Sampler:</b> Jeremy Fox
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b>
<b>PO Number:</b>	<b>System No.:</b> UTAH20043
<b>Source Code:</b> DS001	<b>Sample Point:</b> DS001
	<b>Report to State:</b> Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0094	1.3	0.0012	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	



# Certificate of Analysis

**CHEMTECH-FORD**  
LABORATORIES

Lab Sample No.: 24L1391-04

<b>Name:</b> Skyline Mountain Special Services District	<b>Sample Date:</b> 12/17/2024 8:30 AM
<b>Sample Site:</b> Lot-C 05	<b>Receipt Date:</b> 12/17/2024 1:30 PM
<b>Comments:</b>	<b>Sampler:</b> Jeremy Fox
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b>
<b>PO Number:</b>	<b>System No.:</b> UTAH20043
<b>Source Code:</b> DS001	<b>Sample Point:</b> DS001
	<b>Report to State:</b> Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0083	1.3	0.0012	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	



# Certificate of Analysis

**CHEMTECH-FORD**  
LABORATORIES

**Lab Sample No.:** 24L1391-05

<b>Name:</b> Skyline Mountain Special Services District	<b>Sample Date:</b> 12/17/2024 9:30 AM
<b>Sample Site:</b> Lot-C 50	<b>Receipt Date:</b> 12/17/2024 1:30 PM
<b>Comments:</b>	<b>Sampler:</b> Jeremy Fox
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b>
<b>PO Number:</b>	<b>System No.:</b> UTAH20043
<b>Source Code:</b> DS001	<b>Sample Point:</b> DS001
	<b>Report to State:</b> Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0086	1.3	0.0012	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8/200.8	12/18/2024	12/18/2024	



CHEMTECH-FORD  
LABORATORIES

## Certificate of Analysis

### Report Footnotes

#### Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.  
1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.  
1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.  
1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.  
Values reported in **BLUE** exceed Secondary Drinking Water standards.  
**BLANK** values in the MCL column indicate no standard.  
On calculated parameters, there may be a slight difference between summing the rounded values shown on the report vs the unrounded values used in the calculation.

