

## Certificate of Analysis

### Skyline Mountain Special Services District

Attn: Roy Fox  
2201 SMR  
Fairview, UT 84629

Work Order: 23H0574  
Phone: (801) 361-6227  
Fax:  
Email: smssd2013@gmail.com

Lab #: 23H0574-01

Sample ID: Lot C-49

**Report to State: Yes**

Sample Type: Routine

Sampled: 8/7/23 11:53

Sampled By: Jeremy Fox

Field Res. Chlorine: Not Provided

System #: UTAH20043

Sample Source: DS001

Sample Point: DS001

Repeat Lab:

Original Failure Date:

Parameter Name	Result	Units	Method	Test Started	Test Ended	Flags
Coliform, Total	Absent	Org/100 mL	EPA 9223B	8/7/2023 15:30	8/8/2023 9:45	
E. Coli	Absent	Org/100 mL	EPA 9223B	8/7/2023 15:30	8/8/2023 9:45	

Lab #: 23H0574-02

Sample ID: Thads Peak

**Report to State: Yes**

Sample Type: Routine

Sampled: 8/7/23 12:18

Sampled By: Jeremy Fox

Field Res. Chlorine: Not Provided

System #: UTAH20043

Sample Source: DS001

Sample Point: DS001

Repeat Lab:

Original Failure Date:

Parameter Name	Result	Units	Method	Test Started	Test Ended	Flags
Coliform, Total	Absent	Org/100 mL	EPA 9223B	8/7/2023 15:30	8/8/2023 9:45	
E. Coli	Absent	Org/100 mL	EPA 9223B	8/7/2023 15:30	8/8/2023 9:45	




Joyce Applegate, Project Manager

