



Timpview Analytical Laboratories

A Chemtech-Ford, Inc. Affiliate
1384 West 130 South Orem, UT 84058 (801) 229-2282



Certificate of Analysis

Skyline Mountain Special Services District
Roy Fox
2201 SMR
Fairview, UT 84629
DW System # : UTAH20043

Work Order #: 18F1041
PO# / Project Name:
Receipt: 6/19/18 13:20
Batch Temp °C: 10.8
Date Reported: 6/26/2018

Sample Name: Thad's Peak

Collected: 6/19/18 10:45

Matrix: Drinking Water

Collected By: Jeremy Fox

Parameter	Lab ID #	Method	Analysis		Result	Units	MRL	Flags
			Date / Time					
Coliform, Total	18F1041-01	EPA 9223B	6/20/18	14:56	Absent	Org/100 mL	1	
E. Coli	18F1041-01	EPA 9223B	6/20/18	14:56	Absent	Org/100 mL	1	

Comment:

Sample Name: Lot C-49

Collected: 6/19/18 10:30

Matrix: Drinking Water

Collected By: Jeremy Fox

Parameter	Lab ID #	Method	Analysis		Result	Units	MRL	Flags
			Date / Time					
Coliform, Total	18F1041-02	EPA 9223B	6/20/18	14:56	Absent	Org/100 mL	1	
E. Coli	18F1041-02	EPA 9223B	6/20/18	14:56	Absent	Org/100 mL	1	

Comment:

Sample Name: Thad's Peak Well

Collected: 6/19/18 10:45

Matrix: Drinking Water

Collected By: Jeremy Fox

Parameter	Lab ID #	Method	Analysis		Result	Units	MRL	Flags
			Date / Time					
Nitrate as N	18F1041-03	EPA 300.0	6/19/18	22:07	0.8	mg/L	0.1	

Comment:

Sample Name: Golf Course Well

Collected: 6/19/18 11:10

Matrix: Drinking Water

Collected By: Jeremy Fox

Parameter	Lab ID #	Method	Analysis		Result	Units	MRL	Flags
			Date / Time					
Nitrate as N	18F1041-04	EPA 300.0	6/19/18	22:48	0.3	mg/L	0.1	

Comment:

Sample Name: Club House Well

Collected: 6/19/18 11:28


Matrix: Drinking Water

Collected By: Jeremy Fox

Parameter	Lab ID #	Method	Analysis		Result	Units	MRL	Flags
			Date / Time					
Nitrate as N	18F1041-05	EPA 300.0	6/19/18	23:29	0.1	mg/L	0.1	

Comment:

Analyses presented in this report were performed in accordance with the National Environmental Laboratory Accreditation Program by a Chemtech-Ford affiliate company, except where otherwise noted.



Timpview Analytical Laboratories

A Chemtech-Ford, Inc. Affiliate

1384 West 130 South

Orem, UT 84058

(801) 229-2282



Certificate of Analysis

Skyline Mountain Special Services District

Roy Fox

2201 SMR

Fairview, UT 84629

DW System # : UTAH20043

Work Order #: 18F1041

PO# / Project Name:

Receipt: 6/19/18 13:20

Batch Temp °C: 10.8

Date Reported: 6/26/2018

Reviewed by:

Joyce Applegate, Project Manager

Analyses presented in this report were performed in accordance with the National Environmental Laboratory Accreditation Program by a Chemtech-Ford affiliate company, except where otherwise noted.