

7/5/2022

Work Order: 22F2163
Project: [none]

Skyline Mountain Special Services District

Attn: Roy Fox

2201 SMR

Fairview, UT 84629


Client Service Contact: 801.229.2282

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Joyce Applegate, Project Manager



A ChemtechFord Affiliate


Certificate of Analysis



Lab Sample No.: 22F2163-01

Name: Skyline Mountain Special Services District	Sample Date: 6/23/2022 11:30 AM
Sample Site: Clubhouse Well	Receipt Date: 6/23/2022 3:06 PM
Comments:	Sampler: Jeremy Fox
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH20043
Source Code: WS001	Sample Point: WS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Cyanide, Total	0.003	0.2	0.002	mg/L	SM 4500 CN-E	06/28/2022	06/28/2022	
Fluoride	0.10	4	0.10	mg/L	EPA 300.0	06/23/2022	06/24/2022	
Nitrate as N	0.2	10	0.1	mg/L	EPA 300.0	06/23/2022 16:33	06/24/2022 10:39	
Sulfate	17.3	250	10.0	mg/L	EPA 300.0	06/23/2022	06/24/2022	
Total Dissolved Solids (TDS)	268	1000	20	mg/L	SM 2540 C	06/24/2022	06/24/2022	
Turbidity	ND	5	0.05	NTU	EPA 180.1	06/24/2022 09:59	06/24/2022 11:20	
Metals								
Antimony, Total	ND	0.006	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Arsenic, Total	ND	0.01	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Barium, Total	0.094	2	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Beryllium, Total	ND	0.004	0.001	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Cadmium, Total	ND	0.005	0.0002	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Chromium, Total	ND	0.1	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Mercury, Total	ND	0.002	0.00020	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Nickel, Total	ND	0.1	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Selenium, Total	ND	0.05	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Sodium, Total	14.1		0.5	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Thallium, Total	ND	0.002	0.0002	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Carbamates								
3-Hydroxycarbofuran	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb sulfone	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb sulfoxide	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Carbaryl	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Carbofuran	ND	40	1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Methomyl	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Oxamyl	ND	200	1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Herbicides								
2,4,5-TP (Silvex)	ND	50	0.440	ug/L	EPA 515.3	06/28/2022	06/30/2022	
2,4-D	ND	70	0.220	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dalapon	ND	200	2.20	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dicamba	ND		1.00	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dinoseb	ND	7	0.440	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Pentachlorophenol	ND	1	0.088	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Picloram	ND	500	0.220	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Pesticides								



A ChemtechFord Affiliate

Certificate of Analysis



Lab Sample No.: 22F2163-01

Name: Skyline Mountain Special Services District	Sample Date: 6/23/2022 11:30 AM
Sample Site: Clubhouse Well	Receipt Date: 6/23/2022 3:06 PM
Comments:	Sampler: Jeremy Fox
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH20043
Source Code: WS001	Sample Point: WS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Pesticides (cont.)								
Endrin	ND	2	0.022	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Heptachlor	ND	0.4	0.088	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Heptachlor epoxide	ND	0.2	0.044	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Lindane	ND	0.2	0.044	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Methoxychlor	ND	40	0.22	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1016	ND	0.2	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1221	ND	0.5	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1232	ND	0.5	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1242	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1248	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1254	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1260	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB - Total	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Toxaphene	ND	3	2.2	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Semi-Volatile Compounds								
Alachlor	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Aldrin	ND		2.00	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Atrazine	ND	3	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Benzo (a) pyrene	ND	0.2	0.04	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Bis (2-ethylhexyl) Adipate	ND	400	1.30	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Bis (2-ethylhexyl) Phthalate	ND	6	1.30	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Butachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
alpha-Chlordane	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
gamma-Chlordane	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Chlordane - Total	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Dieldrin	ND		1.00	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Hexachlorobenzene	ND	1	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Hexachlorocyclopentadiene	ND	50	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Metolachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Metribuzin	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Propachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Simazine	ND	4	0.15	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Volatile Organic Compounds								
1,1,1,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,1-Trichloroethane	ND	200	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,2,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,2-Trichloroethane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate


Certificate of Analysis



Lab Sample No.: 22F2163-01

Name: Skyline Mountain Special Services District	Sample Date: 6/23/2022 11:30 AM
Sample Site: Clubhouse Well	Receipt Date: 6/23/2022 3:06 PM
Comments:	Sampler: Jeremy Fox
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH20043
Source Code: WS001	Sample Point: WS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
1,1,2-Trichlorotrifluoroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloroethene	ND	7	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloropropene	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,3-Trichlorobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,3-Trichloropropane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,4-Trichlorobenzene	ND	70	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,4-Trimethylbenzene	ND	70	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichlorobenzene	ND	600	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichloroethane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichloropropane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3,5-Trimethylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3-Dichlorobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3-Dichloropropane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,4-Dichlorobenzene	ND	75	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
2,2-Dichloropropane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
2-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
4-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Benzene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromochloromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromodichloromethane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromoform	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromomethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Carbon Tetrachloride	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chlorobenzene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloroform	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
cis-1,2-Dichloroethene	ND	70	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
cis-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dibromochloromethane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dibromomethane	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dichlorodifluoromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Ethyl Benzene	ND	700	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	J-LOW
Hexachlorobutadiene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Isopropylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Methyl tert-Butyl Ether (MTBE)	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Methylene Chloride	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate

Certificate of Analysis



Lab Sample No.: 22F2163-01

Name: Skyline Mountain Special Services District	Sample Date: 6/23/2022 11:30 AM
Sample Site: Clubhouse Well	Receipt Date: 6/23/2022 3:06 PM
Comments:	Sampler: Jeremy Fox
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH20043
Source Code: WS001	Sample Point: WS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
Naphthalene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
n-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
n-Propyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
p-Isopropyltoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
sec-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Styrene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
tert-Butylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Tetrachloroethene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Toluene	ND	1000	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
trans-1,2-Dichloroethene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
trans-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Trichloroethene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Trichlorofluoromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Vinyl Chloride	ND	2	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Xylenes, total	ND	10000	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	

Lab Sample No.: 22F2163-02

Name: Skyline Mountain Special Services District

Sample Date: 6/23/2022 12:00 PM

Sample Site: Golf Course Well

Receipt Date: 6/23/2022 3:06 PM

Comments:

Sampler: Jeremy Fox

Sample Matrix: Drinking Water

Project:

PO Number:

System No.: UTAH20043

Source Code: WS003

Sample Point: WS003

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Cyanide, Total	ND	0.2	0.002	mg/L	SM 4500 CN-E	06/28/2022	06/28/2022	
Fluoride	0.18	4	0.10	mg/L	EPA 300.0	06/23/2022	06/24/2022	
Nitrate as N	0.4	10	0.1	mg/L	EPA 300.0	06/23/2022 16:33	06/24/2022 11:20	
Sulfate	17.4	250	1.0	mg/L	EPA 300.0	06/23/2022	06/24/2022	
Total Dissolved Solids (TDS)	276	1000	20	mg/L	SM 2540 C	06/24/2022	06/24/2022	
Turbidity	ND	5	0.05	NTU	EPA 180.1	06/24/2022 09:59	06/24/2022 11:21	
Metals								
Antimony, Total	ND	0.006	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Arsenic, Total	ND	0.01	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Barium, Total	0.086	2	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Beryllium, Total	ND	0.004	0.001	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Cadmium, Total	ND	0.005	0.0002	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Chromium, Total	ND	0.1	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Mercury, Total	ND	0.002	0.00020	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Nickel, Total	ND	0.1	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Selenium, Total	ND	0.05	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Sodium, Total	16.3		0.5	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Thallium, Total	ND	0.002	0.0002	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Carbamates								
3-Hydroxycarbofuran	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb sulfone	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb sulfoxide	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Carbaryl	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Carbofuran	ND	40	1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Methomyl	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Oxamyl	ND	200	1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Herbicides								
2,4,5-TP (Silvex)	ND	50	0.440	ug/L	EPA 515.3	06/28/2022	06/30/2022	
2,4-D	ND	70	0.220	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dalapon	ND	200	2.20	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dicamba	ND		1.00	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dinoseb	ND	7	0.440	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Pentachlorophenol	ND	1	0.088	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Picloram	ND	500	0.220	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Pesticides								

Lab Sample No.: 22F2163-02

Name: Skyline Mountain Special Services District

Sample Date: 6/23/2022 12:00 PM

Sample Site: Golf Course Well

Receipt Date: 6/23/2022 3:06 PM

Comments:

Sampler: Jeremy Fox

Sample Matrix: Drinking Water

Project:

PO Number:

System No.: UTAH20043

Source Code: WS003

Sample Point: WS003

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Pesticides (cont.)								
Endrin	ND	2	0.022	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Heptachlor	ND	0.4	0.088	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Heptachlor epoxide	ND	0.2	0.044	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Lindane	ND	0.2	0.044	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Methoxychlor	ND	40	0.22	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1016	ND	0.2	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1221	ND	0.5	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1232	ND	0.5	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1242	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1248	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1254	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1260	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB - Total	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Toxaphene	ND	3	2.2	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Semi-Volatile Compounds								
Alachlor	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Aldrin	ND		2.00	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Atrazine	ND	3	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Benzo (a) pyrene	ND	0.2	0.04	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Bis (2-ethylhexyl) Adipate	ND	400	1.30	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Bis (2-ethylhexyl) Phthalate	ND	6	1.30	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Butachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
alpha-Chlordane	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
gamma-Chlordane	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Chlordane - Total	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Dieldrin	ND		1.00	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Hexachlorobenzene	ND	1	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Hexachlorocyclopentadiene	ND	50	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Metolachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Metribuzin	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Propachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Simazine	ND	4	0.15	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Volatile Organic Compounds								
1,1,1,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,1-Trichloroethane	ND	200	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,2,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,2-Trichloroethane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate

Certificate of Analysis



Lab Sample No.: 22F2163-02

Name: Skyline Mountain Special Services District

Sample Date: 6/23/2022 12:00 PM

Sample Site: Golf Course Well

Receipt Date: 6/23/2022 3:06 PM

Comments:

Sampler: Jeremy Fox

Sample Matrix: Drinking Water

Project:

PO Number:


System No.: UTAH20043

Source Code: WS003

Sample Point: WS003

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
1,1,2-Trichlorotrifluoroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloroethene	ND	7	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloropropene	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,3-Trichlorobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,3-Trichloropropane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,4-Trichlorobenzene	ND	70	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,4-Trimethylbenzene	ND	70	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichlorobenzene	ND	600	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichloroethane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichloropropane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3,5-Trimethylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3-Dichlorobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3-Dichloropropane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,4-Dichlorobenzene	ND	75	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
2,2-Dichloropropane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
2-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
4-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Benzene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromochloromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromodichloromethane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromoform	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromomethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Carbon Tetrachloride	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chlorobenzene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloroform	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
cis-1,2-Dichloroethene	ND	70	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
cis-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dibromochloromethane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dibromomethane	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dichlorodifluoromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Ethyl Benzene	ND	700	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	J-LOW
Hexachlorobutadiene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Isopropylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Methyl tert-Butyl Ether (MTBE)	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Methylene Chloride	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate

Certificate of Analysis




Lab Sample No.: 22F2163-02

Name: Skyline Mountain Special Services District
Sample Site: Golf Course Well
Comments:
Sample Matrix: Drinking Water
PO Number:
Source Code: WS003

Sample Date: 6/23/2022 12:00 PM
Receipt Date: 6/23/2022 3:06 PM
Sampler: Jeremy Fox
Project:
System No.: UTAH20043
Report to State: Y

Sample Point: WS003

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
Naphthalene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
n-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
n-Propyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
p-Isopropyltoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
sec-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Styrene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
tert-Butylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Tetrachloroethene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Toluene	ND	1000	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
trans-1,2-Dichloroethene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
trans-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Trichloroethene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Trichlorofluoromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Vinyl Chloride	ND	2	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Xylenes, total	ND	10000	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate

Certificate of Analysis



Lab Sample No.: 22F2163-03

Name: Skyline Mountain Special Services District

Sample Date: 6/23/2022 1:00 PM

Sample Site: Thads Peak Well

Receipt Date: 6/23/2022 3:06 PM

Comments:

Sampler: Jeremy Fox

Sample Matrix: Drinking Water

Project:

PO Number:

System No.: UTAH20043

Source Code: WS002

Sample Point: WS002

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Inorganic								
Cyanide, Total	ND	0.2	0.002	mg/L	SM 4500 CN-E	06/28/2022	06/28/2022	
Fluoride	0.15	4	0.10	mg/L	EPA 300.0	06/23/2022	06/24/2022	
Nitrate as N	0.9	10	0.1	mg/L	EPA 300.0	06/23/2022 16:33	06/24/2022 11:40	
Sulfate	2.7	250	1.0	mg/L	EPA 300.0	06/23/2022	06/24/2022	
Total Dissolved Solids (TDS)	360	1000	20	mg/L	SM 2540 C	06/24/2022	06/24/2022	
Turbidity	ND	5	0.05	NTU	EPA 180.1	06/24/2022 09:59	06/24/2022 11:22	
Metals								
Antimony, Total	ND	0.006	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Arsenic, Total	ND	0.01	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Barium, Total	0.215	2	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Beryllium, Total	ND	0.004	0.001	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Cadmium, Total	ND	0.005	0.0002	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Chromium, Total	ND	0.1	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Mercury, Total	ND	0.002	0.00020	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Nickel, Total	ND	0.1	0.005	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Selenium, Total	ND	0.05	0.0005	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Sodium, Total	1.6		0.5	mg/L	EPA 200.7	06/29/2022	06/29/2022	
Thallium, Total	ND	0.002	0.0002	mg/L	EPA 200.8	06/27/2022	06/27/2022	
Carbamates								
3-Hydroxycarbofuran	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb sulfone	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Aldicarb sulfoxide	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Carbaryl	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Carbofuran	ND	40	1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Methomyl	ND		1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Oxamyl	ND	200	1	ug/L	EPA 531.1	06/27/2022	06/27/2022	
Herbicides								
2,4,5-TP (Silvex)	ND	50	0.440	ug/L	EPA 515.3	06/28/2022	06/30/2022	
2,4-D	ND	70	0.220	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dalapon	ND	200	2.20	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dicamba	ND		1.00	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Dinoseb	ND	7	0.440	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Pentachlorophenol	ND	1	0.088	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Picloram	ND	500	0.220	ug/L	EPA 515.3	06/28/2022	06/30/2022	
Pesticides								

Lab Sample No.: 22F2163-03

Name: Skyline Mountain Special Services District

Sample Date: 6/23/2022 1:00 PM

Sample Site: Thads Peak Well

Receipt Date: 6/23/2022 3:06 PM

Comments:

Sampler: Jeremy Fox

Sample Matrix: Drinking Water

Project:

PO Number:


System No.: UTAH20043

Source Code: WS002

Sample Point: WS002

Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Pesticides (cont.)								
Endrin	ND	2	0.022	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Heptachlor	ND	0.4	0.088	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Heptachlor epoxide	ND	0.2	0.044	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Lindane	ND	0.2	0.044	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Methoxychlor	ND	40	0.22	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1016	ND	0.2	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1221	ND	0.5	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1232	ND	0.5	0.20	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1242	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1248	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1254	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB-1260	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
PCB - Total	ND	0.5	0.50	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Toxaphene	ND	3	2.2	ug/L	EPA 508.1	06/28/2022	06/30/2022	
Semi-Volatile Compounds								
Alachlor	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Aldrin	ND		2.00	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Atrazine	ND	3	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Benzo (a) pyrene	ND	0.2	0.04	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Bis (2-ethylhexyl) Adipate	ND	400	1.30	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Bis (2-ethylhexyl) Phthalate	ND	6	1.30	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Butachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
alpha-Chlordane	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
gamma-Chlordane	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Chlordane - Total	ND	2	0.44	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Dieldrin	ND		1.00	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Hexachlorobenzene	ND	1	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Hexachlorocyclopentadiene	ND	50	0.22	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Metolachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Metribuzin	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Propachlor	ND		0.50	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Simazine	ND	4	0.15	ug/L	EPA 525.2	06/28/2022	06/30/2022	
Volatile Organic Compounds								
1,1,1,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,1-Trichloroethane	ND	200	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,2,2-Tetrachloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1,2-Trichloroethane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate


Certificate of Analysis



Lab Sample No.: 22F2163-03

Name: Skyline Mountain Special Services District	Sample Date: 6/23/2022 1:00 PM
Sample Site: Thads Peak Well	Receipt Date: 6/23/2022 3:06 PM
Comments:	Sampler: Jeremy Fox
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH20043
Source Code: WS002	Sample Point: WS002
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
1,1,2-Trichlorotrifluoroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloroethene	ND	7	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,1-Dichloropropene	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,3-Trichlorobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,3-Trichloropropane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,4-Trichlorobenzene	ND	70	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2,4-Trimethylbenzene	ND	70	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichlorobenzene	ND	600	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichloroethane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,2-Dichloropropane	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3,5-Trimethylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3-Dichlorobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,3-Dichloropropane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
1,4-Dichlorobenzene	ND	75	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
2,2-Dichloropropane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
2-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
4-Chlorotoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Benzene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromobenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromochloromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromodichloromethane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromoform	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Bromomethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Carbon Tetrachloride	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chlorobenzene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloroethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloroform	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Chloromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
cis-1,2-Dichloroethene	ND	70	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
cis-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dibromochloromethane	ND		0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dibromomethane	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Dichlorodifluoromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Ethyl Benzene	ND	700	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	J-LOW
Hexachlorobutadiene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Isopropylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Methyl tert-Butyl Ether (MTBE)	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Methylene Chloride	ND	5	1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate


Certificate of Analysis



Lab Sample No.: 22F2163-03

Name: Skyline Mountain Special Services District	Sample Date: 6/23/2022 1:00 PM
Sample Site: Thads Peak Well	Receipt Date: 6/23/2022 3:06 PM
Comments:	Sampler: Jeremy Fox
Sample Matrix: Drinking Water	Project:
PO Number:	System No.: UTAH20043
Source Code: WS002	Sample Point: WS002
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Volatile Organic Compounds (cont.)								
Naphthalene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
n-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
n-Propyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
p-Isopropyltoluene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
sec-Butyl Benzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Styrene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
tert-Butylbenzene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Tetrachloroethene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Toluene	ND	1000	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
trans-1,2-Dichloroethene	ND	100	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
trans-1,3-Dichloropropene	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Trichloroethene	ND	5	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Trichlorofluoromethane	ND		1.0	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Vinyl Chloride	ND	2	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	
Xylenes, total	ND	10000	0.5	ug/L	EPA 524.2	06/28/2022	06/28/2022	



A ChemtechFord Affiliate

Certificate of Analysis



Analyses presented in this report were performed in accordance with the National Environmental Laboratory Accreditation Program by a Chemtech-Ford affiliate company, except where otherwise noted.

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Flag Descriptions

J-LOW = Estimated low due to low recovery of LCS or CCV

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

BLANK values in the MCL column indicate no standard.

CHAIN OF CUSTODY - SAMPLE SUBMITTAL FORM DRINKING WATER



CHEMTECH-FORD
LABORATORIES

Chemtech-Ford Laboratories
9632 South 500 West
Sandy, UT 84070
Phone: 801-262-7289
www.chemtechford.com

Expedited turnaround, subject to additional charges

COMPANY: SMSSD

ADDRESS: _____

CITY/STATE/ZIP: _____

PHONE #: _____

CONTACT: Rox Fox

EMAIL: _____

PROJECT: _____

PO Number: _____

INVOICE EMAIL ADDRESS: _____

State System # <u>Utch 20043</u>	Rush Due Date: _____
Send to State <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Sample condition <input checked="" type="checkbox"/> Correct Containers <input checked="" type="checkbox"/> Sufficient Sample Volume <input type="checkbox"/> Headspace Present (VOC) <input type="checkbox"/> Temperature Blank <input checked="" type="checkbox"/> Received within Holding Time	Delivery Method <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input checked="" type="checkbox"/> Walk-in <input type="checkbox"/> Chemtech-Ford Courier <input type="checkbox"/> Customer Courier
--	---

Lab Use Only	LOCATION / IDENTIFICATION	DATE	TIME	FACILITY ID (Source Code)	POINT CODE (DBP)
22F21G3	01 Club House	6/23/22	1130		
	02 Golf Course	6/23/22	1700		
	03 Theds Peak	6/23/22	1800		

TESTS REQUESTED	Field: Residual Chlorine	Total Coliform + E coli (Absent present)	Total Coliform + E coli (enumerated)	HPC (Plate Count)	Bacteria	Fail Ref Lab WO #
<input checked="" type="checkbox"/> Pesticide					R = Routine I = Investigative TR = Trigger Source RP = Repeat	
<input checked="" type="checkbox"/> INOR AMBs					Repeat OR - Original UP - Upstream DN - Downstream	
<input checked="" type="checkbox"/> Nitrate						
<input checked="" type="checkbox"/> UACs						
<input checked="" type="checkbox"/>						
<input checked="" type="checkbox"/>						
<input checked="" type="checkbox"/>						
<input checked="" type="checkbox"/>						
<input checked="" type="checkbox"/>						
<input checked="" type="checkbox"/>						

Sample by: [print] <u>Jeremy Fox</u> Special Instructions: _____	Sample by: [signature] <u>[Signature]</u>	Date/Time <u>6/23/22 1506</u>	Date/Time <u>6-23-22 1506</u>
Relinquished by: [signature] <u>[Signature]</u>	Relinquished by: [signature] <u>[Signature]</u>	Date/Time <u>6/23/22 1506</u>	Date/Time <u>6-23-22 1506</u>
Relinquished by: [signature] _____	Relinquished by: [signature] _____	Date/Time _____	Date/Time _____

ON ICE NOT ON ICE Temp (C°): 9.1

Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum). Client agrees to pay collection costs and attorney's fees.

