

Annual Drinking Water Quality Report -2012-

Skyline Mountain Special Service District
2201 Skyline Mountain Resort
Fairview, UT 84629

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is ground water which we get from two wells.

SOURCE PROTECTION PLAN

The Drinking Water Source Protection Plan for Skyline Mountain SSD is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Potential contamination sources common in our protection areas are roads and residential areas. Our sources have a low level of susceptibility to potential contamination. We have also developed management strategies to further protect our sources from contamination. Please contact us if you have questions or concerns about our source protection plan.

CROSS CONNECTION CONTROL

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality, of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

I'm pleased to report that our drinking water meets federal and state requirements.

QUESTIONS

This report shows our water quality and what it means to you our customer. If you have any questions about this report or concerning your water utility, please Everett Taylor at 435-427-9590.

PLEASE ATTEND

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on second Wednesday of every month except for the winter which is every other month. These meetings begin at 7:00pm at the Resort Club House.

Skyline Mountain SSD routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2012 or the most recent sample data. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

CONSTITUENT TABLE DEFINITIONS

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - Laboratory analysis indicates that the constituent is not present.

ND/Low - High - For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or Milligrams per liter (mg/l) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - Measure of radiation absorbed by the body.

Million Fibers per Liter (MFL) - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem out-dated.

Waivers (W)- Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.

CONSTITUENT TABLE - TEST RESULTS

CONTAMINANT	VIOL. Y/N	LEVEL DETECTED	UNIT MEAS.	MCLG	MCL	DATE SAMPLED	LIKELY SOURCE OF CONTAMINATION
MICROBIOLOGICAL CONTAMINANTS							
Total Coliform Bacteria	N	ND	N/A	0	*See Below	2011	Naturally present in the environment
*Presence of coliform bacteria in 5% of monthly samples							
Fecal coliform and E.coli	N	ND	N/A	0	**See Below	2011	Human and animal fecal waste
**If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive							
RADIOLOGICAL CONTAMINANTS							

Alpha emitters	N	1-2	pCi/l	0	15	2008	Erosion of natural deposits
Radium-228	N	ND-1	pCi/l	0	5	2009	Erosion of natural deposits
INORGANIC CONTAMINANTS							
Barium	N	87-184	ppb	2,000	2,000	2010	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium	N	5	ppb	100	100	2010	Discharge from steel and pulp mills; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a. 125 b. 0	ppt	1,300,000	AL= 1,300,000	2011	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride	N	100-200	ppb	4,000	4,000	2010	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. 2 b. 0	ppt	0	AL= 15,000	2011	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	5	ppb	100	100	2010	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate (as Nitrogen)	N	500-1,000	ppb	10,000	10,000	2011	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium	N	2-17	ppm	20	None set by EPA	2010	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills.
Sulfate	N	2-20	ppm	1,000	1,000	2010	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills, runoff from cropland
Total Dissolved Solids (TDS)	N	303-307	ppm	2,000	2,000	2010	Erosion of natural deposits
SIGNIFICANT PHYSICAL DEFICIENCY (SIG)							
Quote SIG from IPS				SURVEY DATE		ACTION PLAN	
*Failure to provide 20 psi to all connections				09/09/2012		Skyline Mountain SSD is currently working with the state on a correction action plan to meet the psi requirements.	

We periodically monitor for Nitrate in the water supply to meet all regulatory requirements. In 2012 we failed to take the required samples. Testing for Nitrate is used to ensure that the public is provided with safe drinking water. This violation does not necessarily pose a health risk. We have reviewed why we failed to take the required samples and will take steps to ensure that it will not happen again.

We periodically monitor for Volatile Organic chemical constituents in the water supply to meet all regulatory requirements. In 2012 we failed to take the required samples. Testing for Volatile Organic chemicals is used to ensure that the public is provided with safe drinking water. This violation does not necessarily pose a health risk. We have reviewed why we failed to take the required samples and will take steps to ensure that it will not happen again.

LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Skyline Mountain SSD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

SAFE WATER

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or are man made. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We at Skyline Mountain SSD work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Skyline Mountain SSD
2201 SMR
Fairview, Utah 84629

February 26, 2013

Patti Fauver
CCR Compliance
Division of Drinking Water
P.O. Box 144830
Salt Lake City, Utah 84114-4830

Dear Ms. Fauver:

Subject: Consumer Confidence Report for Skyline Mountain SSD - 20043

Enclosed is a copy of Skyline Mountain SSD Consumer Confidence Report. It contains the water quality information for our water system for the calendar year 2012 or the most recent sample data.

We have delivered this report to our customers by posting a notice in our newsletter and have a copy at the office upon request.

If you have any questions, please contact me at 435-427-9590.

Sincerely,

Everett Taylor
Skyline Mountain SSD